


- GENERAL NOTES :**
1. ALL ELECTRICAL WORKS SHALL BE DONE IN ACCORDANCE WITH THE PROVISION OF THE LATEST EDITION OF THE PHILIPPINE ELECTRICAL CODE, EXISTING APPLICABLE ORDINANCES, RULES AND REGULATIONS OF THE LOCAL GOVERNMENT AND WITH THE REQUIREMENTS OF THE LOCAL POWER COMPANY.
 2. THE TYPE OF SERVICE POWER SUPPLY TO BE USED SHALL BE SINGLE-PHASE, 2-WIRE, 230V, 60 HERTZ, A.C.
 3. THE CONTRACTOR SHALL VERIFY AND ORIENT THE ACTUAL LOCATION OF SERVICE ENTRANCE FOR CONNECTION TO THE POWER COMPANY SERVICE POINT.
 4. UNLESS OTHERWISE SPECIFIED, THE MINIMUM SIZES OF WIRE AND GALVANIZED RIGID STEEL CONDUIT TO BE USED SHALL BE 3.5mm², THHN AND 15mm NOMINAL DIAMETER, RESPECTIVELY, LIKEWISE ALL ELECTRICAL WIRES SHALL BE COLOR-CODED.
 5. ALL LIGHTING CIRCUIT HOMERUNS AND CONVENIENCE OUTLETS SHALL BE WIRED WITH NOT LESS THAN 3.5mm² IN SIZE.
 6. WHEREVER REQUIRED AND NECESSARY, PULL OR JUNCTION BOXES SHALL BE INSTALLED AT CONVENIENT AND INCONSPICUOUS LOCATION. ALTHOUGH SUCH BOXES ARE NOT SHOWN ON THE PLAN NOR MENTIONED IN THE SPECIFICATION.
 7. ALL NON-CURRENT CARRYING METAL PARTS OF ELECTRICAL EQUIPMENT SHALL BE PROPERLY GROUNDED IN ACCORDANCE WITH THE PROVISIONS IN ARTICLE 2.50 "GROUNDING" PHILIPPINE ELECTRICAL CODE, VOLUME 1, 2000 EDITION.
 8. ALL MATERIALS TO BE USED SHALL BE BRAND NEW AND OF THE APPROVED TYPE FOR THE LOCATION AND PURPOSE.
 9. STANDARD TYPE OF ACCESSORIES, SPLICING DEVICES, TERMINATIONS AND OTHER APPURTENANCES FOR THE ENTIRE ELECTRICAL INSTALLATION SHALL BE USED.
 10. ALL WALL OUTLETS SHALL BE INSTALLED AT THE FOLLOWING HEIGHTS ABOVE THE FINISHED FLOOR LEVEL UNLESS NOTED IN THE PLANS.
 - a.) WALL SWITCHES @ 1200mm
 - b.) WALL CONVENIENCE OUTLETS @ 300 mm OR 150mm ABOVE WORKTABLE AND COUNTER
 11. ALL ELECTRICAL WORKS SHALL BE DONE UNDER THE DIRECT AND IMMEDIATE SUPERVISION OF A DULY REGISTERED ELECTRICAL ENGINEER.



ELECTRICAL LAYOUT
 SCALE : _____ NTS.

	SIGNATURE & SEAL	PROJECT TITLE:	OWNER/S:	SHEET CONTENTS :	SHEET NO. :
SOUTHERN LEYTE STATE UNIVERSITY MAIN CAMPUS	_____ ARCHITECT PRC #: _____ DATE: _____ PTR #: _____ DATE: _____ UAP #: _____ TIN #: _____ PLACE ISSUED: SOGOD SOUTHERN LEYTE, PHILIPPINES	SLSU-Main KITCHEN HUB		AS SHOWN	
		LOCATION: BRGY. SAN ROQUE, SOGOD SOUTHERN LEYTE	ADDRESS : BRGY. SAN ROQUE, SOGOD SOUTHERN LEYTE	CADD BY : D.A.B.A.	